

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL

No. 22

Approved

January 13, 1984

RESOLVED, That permission is hereby granted to Jason Grant of T & K Realty, 86 Weybosset Street, Providence, Rhode Island, to construct a handicapped ramp at 91 Globe Street, all in accordance with conditions as set forth by the Director of Inspection and Standards.

IN CITY COUNCIL

JAN 5 1984
READ AND PASSED

PRES.

[Signature]
[Signature]
Clerk

APPROVED

JAN 13 1984

MAYOR

1953
L. H. H. D.
of the Council

THE COMMITTEE ON

PUBLIC WORKS

Approves Passage of
The Within Resolution

Rose M. Menlowen
Clerk Chairman

December 14, 1953

CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

PETITION TO THE CITY COUNCIL

TO THE HONORABLE CITY COUNCIL OF THE CITY OF PROVIDENCE:

The undersigned respectfully petitions your honorable body

The Original Door Location

Petition to City Council:

To allow the construction of a handicapped ramp on a city sidewalk located at 91 Globe Street.

This building is presently undergoing renovation. There are two rental spaces and a barrier free bathroom on the first floor. These spaces can only be accessed from the entries on the front of the building.

It should be noted that this portion of Globe Street runs a short distance and dead ends at the hurricane barrier. There is only one other building on this street, the former Leaming Building.

Respectfully submitted,

Jason Grant
T+K Realty

Jason Grant
c/o Jay Litman, EXTRADOS Design Associates
86 Weybossett St. Room 612
Providence, R.I. 02903

331-0880

Jim Clark

RECEIVED TO COMMITTEE ON
FIRST READING
OCT 5 1993
IN CITY COUNCIL

COMMITTEE ON

RECOMMENDATION

CITY

FILED

OCT 7 3 30 PM '83

DEPT. OF PUBLIC WORKS
PROVIDENCE, R.I.

IN CITY COUNCIL

OCT 20 1983

FIRST READING

REFERRED TO COMMITTEE ON PUBLIC WORKS

Rose M. Menelaou
CLERK

THE COMMITTEE ON

PUBLIC WORKS

Recommends

Clerk

From the Clerk's Desk

City of Providence



Rhode Island

Department of City Clerk

MEMORANDUM

DATE: October 25, 1983

TO: Merlin DeConti, Director of Inspection and Standards

SUBJECT: HANICAPPED RAMP

CONSIDERED BY: Committee On Public Works

DISPOSITION:

Attached is a copy of the above subject matter, for your study and report back in writing to the said committee.

Michael R. Clement
First Deputy City Clerk

MERLIN A. DeCONTI, JR., P.E.
DIRECTOR



VINCENT A. CIANCI, JR.
MAYOR

DEPARTMENT OF INSPECTION AND STANDARDS

November 16, 1983

Committee on Public Works
City Clerk's Office
City Hall
Providence, Rhode Island

Dear Sirs:

This Department has reviewed the plans for construction of the ramp and the steps at 91 Globe Street and has no objection to the construction as proposed, provided the following corrections are made on the plans.

Railing height must be noted as 42 inches from the landing.

Railings must be spaced no farther apart than 6 inches on center.

Very truly yours,

A handwritten signature in cursive script, reading "Merlin A. DeConti, Jr.", written in dark ink.

Merlin A. DeConti, Jr.
Director

MAD, JR:np