

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL


No. 120


Approved March 22, 1989

RESOLVED, That the Traffic Engineer is requested to retrofit the existing city owned Mercury Vapor Fixtures along Atwells Avenue to 150 Watt High Pressure Sodium.

IN CITY COUNCIL

MAR 16 1989
READ AND PASSED


PRES.


CLERK



Council President Easton, Councilman Glavin
and Councilman Rollins (By Request)



A handwritten signature in dark ink, appearing to read "Joe Paolino".

Department of Inspection and Standards
"Building Pride In Providence"

March 7, 1989

Mr. Nicholas W. Easton
President City Council
Providence City Hall
Providence, RI.

Dear Mr. Easton,

In response to City Council Resolution No. 445, dated July 6, 1987 and as a result of my meeting with the Council members on 2/16/89 I submit the following to you.

My recommendation is that a resolution be placed before the city council to upgrade all the street lighting to High Pressure Sodium. This change would be done with request to Narragansett Electric Company to change over about sixteen hundred fixtures per year. It will take seven to ten years to complete. There is no charge to the city to upgrade to High Pressure Sodium Fixtures.

I would also recommend to you that an additional resolution be presented to the Council to retrofit the existing city owned Mercury Vapor fixtures on Atwells Ave. to 150 watt High Pressure Sodium. This Resolution should go to Traffic Engineers.

If you have any question please don't hesitate to call me.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Joe Walsh".
Joseph H. Walsh
Chief Electrical Inspector

JLW/cw

Council President Easton, Councilman Glavin
and Councilman Rollins (By Request)



Department of Inspection and Standards

"Building Pride In Providence"

March 7, 1989

Mr. Nicholas W. Easton
President City Council
Providence City Hall
Providence, RI.

Dear Mr. Easton,

In response to City Council Resolution No. 445, dated July 6, 1987 and as a result of my meeting with the Council members on 2/16/89 I submit the following to you.

My recommendation is that a resolution be placed before the city council to upgrade all the street lighting to High Pressure Sodium. This change would be done with request to Narragansett Electric Company to change over about sixteen hundred fixtures per year. It will take seven to ten years to complete. There is no charge to the city to upgrade to High Pressure Sodium Fixtures.

I would also recommend to you that an additional resolution be presented to the Council to retrofit the existing city owned Mercury Vapor fixtures on Atwells Ave. to 150 watt High Pressure Sodium. This Resolution should go to Traffic Engineers.

If you have any question please don't hesitate to call me.

Very truly yours,


Joseph H. Walsh

Chief Electrical Inspector

JLW/cw