

RESOLUTION OF THE CITY COUNCIL

No. 541

Approved October 15, 1996

RESOLVED, That the Director of Public Works is requested to repair the road depression at the corner of Oakwood Avenue and Chalkstone Avenue.


IN CITY COUNCIL
OCT 3 1996
READ AND PASSED

Evelyn V. Fargnoli

PRES.

Michael R. Clement

CLERK



Accession No. 100 (By request)

100

100

11/1/96
* Water patch depressed
failed.

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS


RESOLUTION OF THE CITY COUNCIL

No. 541

Approved October 15, 1996

RESOLVED, That the Director of Public Works is requested to repair the road depression at the corner of Oakwood Avenue and Chalkstone Avenue.


A true copy,
Attest:



Michael R. Clement
City Clerk

Nov. 4, 1996

This depression is due to a failed Providence Water Supply Board repair, at the intersection on Oakwood Avenue. THE PWSB has been notified to repair the depression (copy attached).



Ferdinand C. Ihenacho, Dir.

RESOLUTION OF THE CITY COUNCIL

No. 542

Approved October 15, 1996

RESOLVED, That the Director of Public Works is requested to
reset the curbstones in front of 91 Oakwood Avenue.

IN CITY COUNCIL
OCT 3 1996
READ AND PASSED
Stephen V. Fargnoli
PRES.
Michael X. Clement
CLERK

APPROVED
OCT 15 1996
Vincent A. Cianci
MAYOR

Conclusions de Steen (By Request)

* Reset ^{11/1/96} buckled curb

OCT 15 1996


RESOLUTION OF THE CITY COUNCIL

No. 542

Approved October 15, 1996

RESOLVED, That the Director of Public Works is requested to reset the curbstones in front of 91 Oakwood Avenue.


A true copy,
Attest:



Michael R. Clement
City Clerk

Nov. 4, 1996

As a standard operating procedure, the Public works Dept. does not install, remove or reset curbing. The homeowner is responsible to engage a contractor and secure permits to accomplish this work.



Ferdinand C. Ihenacho, Dir.

5
FERDINAND C. IHENACHO, P. E.

~~X JAMES BOZMAN~~
DIRECTOR



VINCENT A. CIANCI, JR.
MAYOR

Department of Public Works

"Building Pride In Providence"

November 9, 1986

Messrs Paul Gadoury & Michael Russo
Dir. Eng. Dir. T & D
Prov. Water Supply Bd.
552 Academy Avenue
Prov., R.I. 02908

Dear Messrs Gadoury & Russo:

Re:

Please be advised that it has come to our attention that the following wtr-patch locations require your department's immediate attention:

Oakwood Ave @ Chalkstone Ave Permit # 649, issued 2/6/82 for
of leak @ 5' (6") water main

Thank you in advance for your cooperation regarding this matter. If we can further assist you in this endeavor, please advise.

Very truly yours.

FERDINAND C. IHENACHO, P.E.
Director of Public Works

CITY COUNCIL
GF CC: F.I., JTM, JLC