

THE CITY OF PROVIDENCE  
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

# RESOLUTION OF THE CITY COUNCIL

No. 288

Approved April 9, 1975

RESOLVED, that the Water Supply Board is requested to cause the portion of sidewalk at 203 Howell Street, broken upon the repair to a water line, to be repaired.

IN CITY COUNCIL  
APR 3 1975

READ AND PASSED

Ralph Targem PRES.  
Vincent Casper CLERK

APPROVED

MAYOR

Vincent Casper  
APR 9 1975

JOHN A. DOHERTY, *Chairman*  
EARL H. ASHLEY  
UGO RICCIO  
ROBERT F. HOWARD  
RAYMOND COLA  
VINCENT J. CIRELLI  
VINCENT T. IZZO, *Ex-Officio*

## WATER SUPPLY BOARD

CITY OF PROVIDENCE, R. I. 02908  
552 ACADEMY AVENUE

JOHN E. ROGERS P.E.  
*Chief Engineer*  
JOHN H. SEITES P.E.  
*Deputy Chief Engineer*  
ROBERT J. PACI  
*Legal Advisor*  
AUSTIN B. McMANUS  
*Secretary*

April 16, 1975

Mr. Vincent Vespia, City Clerk  
City Hall  
Providence, Rhode Island


RE: City Council Resolution No. 288  
Approved April 9, 1975

Dear Mr. Vespia:

On August 27, 1974, this department did excavate in the grass section of the walk in front of 203 Howell Street. This was done to reset the curb box over the curb stop on the water service for this house. The Providence Highway Department, as standard procedure, was notified and requested to make the necessary repairs.

Today, April 16, 1975, this walk was inspected and the grass section was to grade and in good condition. A section of the concrete walk has spalled off and there is a crack, but they are not related to the work done by this department. This is evidence of poor construction at the initial installation.

Very truly yours,



John E. Rogers, P.E.  
Chief Engineer

JER/ms