

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL

No. 140

Approved August 21, 1968

RESOLVED, that the Commissioner of Public Safety is requested to cause a survey to be undertaken to determine if a Crossing-Guard post is needed at the intersection of Pleasant and Hope streets.

IN CITY COUNCIL

AUG 15 1968

READ and PASSED

[Signature]
President
[Signature]
Clerk

APPROVED

AUG 21 1968

[Signature]
MAYOR

RESOLUTION
OF THE
CITY COUNCIL

IN CITY
COUNCIL

APR 18 1968

FIRST READING
REFERRED TO COMMITTEE ON
PUBLIC WELFARE.....

Wm. C. Cooper
CLERK

THE COMMITTEE ON

Public Welfare
Approves Passage of
The Within Resolution

Wm. C. Cooper
Aug 2, 1968
Wm. C. Cooper

Comedian Kelly, by request

HARRY GOLDSTEIN
COMMISSIONER



LEONARD W. REILLY
ADMINISTRATIVE
ASSISTANT

COMMISSIONER OF PUBLIC SAFETY
209 FOUNTAIN ST., PROVIDENCE, RHODE ISLAND 02903

May 14, 1968

The Honorable City Council
City Hall
Providence, Rhode Island

Att: Committee on Public
Welfare

Gentlemen:

In response to a Resolution to establish a crossing guard post at Pleasant and Hope Streets, a survey was made and it was learned that seven children used this crossing. It is not recommended, therefore, that a crossing guard be assigned to this location.

A survey was also conducted at the intersection of Ontario and Niagara Streets where there are 555 crossings during the day, and, despite the fact that there is "boulevard stop" control, the children disregard the flow of traffic and definitely need supervision. It is recommended, therefore, that a crossing guard be assigned to this location; and it will be necessary to increase the number of crossing guards authorized from 94 to 95.

Respectfully submitted,


Commissioner of Public Safety

lr

RESOLUTION
OF THE
CITY COUNCIL

IN CITY
COUNCIL

JUL 8 - 1968

FIRST READING
REFERRED TO COMMITTEE ON
PUBLIC WELFARE
Committee Cooper

THE COMMITTEE ON
Public Welfare
Approves Passage of
The Within Resolution

Committee Cooper
August 1, 1968
Chairman

Commissioner E. Murphy

JAMES T. KILLILEA
CHIEF OF
FIRE DEPARTMENT



HARRY GOLDSTEIN
COMMISSIONER
OF PUBLIC SAFETY

FIRE DEPARTMENT

209 FOUNTAIN ST., PROVIDENCE, RHODE ISLAND 02903

July 30, 1968

From: James T. Killilea, Chief of Department

To: Committee on Public Welfare

Subject: Alarms responded to at certain tax exempt properties

Gentlemen:

In accordance with the resolution of the City Council directing the Chief of the Fire Department to report in writing the number of alarms responded to at certain tax exempt properties and the disposition of any charges brought against persons implicated in arson, the following report is submitted herewith:

James T. Killilea
Chief of Department

JAMES T. KILLILEA
CHIEF OF
FIRE DEPARTMENT



HARRY GOLDSTEIN
COMMISSIONER
OF PUBLIC SAFETY

FIRE DEPARTMENT

209 FOUNTAIN ST., PROVIDENCE, RHODE ISLAND 02903

The following is a list of runs responded to by the Providence Fire Department for the period from June 1, 1967 to May 31, 1968. The property concerned was fire in a building:

<u>Colleges</u>	<u>No. of runs</u>
Brown University	4
Rhode Island School of Design	4
Providence College	1
Bryant College	1
Rhode Island College	2
<u>Private Schools</u>	
Mary C. Wheeler	1
Assumption School	1
St. Augustine's School	1
<u>Hospitals</u>	
Miriam	1
Rhode Island Hospital	2
<u>Church owned property</u>	
St. Michael's Church	1
Holy Cross Church	1
St. John's Episcopal Church	1
Temple Beth Israel	1
<u>Public Property</u>	
United Fund Agency	1
City of Prov. Recreation Dept.	1
City of Prov. Information Booth	1
City Stadium	2
Veterans Auditorium	2
<u>Parks</u>	
Roger Williams Park	7
Merino Park	2
Columbia Park	1
City Hall Park	1

<u>Recreation Centers</u>	<u>No. of Runs</u>
Danford Street	1
Joslin Street	1
Clarence Street	1
Candace Street	1

The following is a list of runs responded to by the Providence Fire Department for the period of June 1, 1967 to May 31, 1968. The property concerned was other than that in a building:

<u>Colleges</u>	<u>No. of Runs</u>
Providence College	41
Brown University	8
Pembroke College	1
Rhode Island School of Design	1
Bryant College	1
Rhode Island College	2
Johnson & Wales Jr. College	9

Private Schools

Moses Brown	3
Providence Hebrew Day	1
St. Charles School	1
St. Xavier High School	1
Lasalle Academy	14
St. Anthony's School	3

Church Owned Property

Assumption Church	1
St. Michael's Church	8
Holy Cross Church	3
St. Thomas Church	2
St. Teresa's Church	12
St. John's Church	1
Holy Rosary Church	1
Our Lady of Mt. Carmel Church	3
Holy Ghost Church	1
St. Johns Ukranian Church	1
Parkside Community Church	1
A.M.E. Zion Church	1
Grace Church	2
St. Stephan's Church	1

Catholic Diocese

Cemetery	4
St. Vincent de Paul	1

<u>Hospitals</u>	<u>No. of Runs</u>
Charles V. Chapin	9
Butler Health Center	4
Rhode Island Hospital	9
St. Joseph's Hospital	1
U.S. Veterans Hospital	12
Lying-In Hospital	3
Miriam Hospital	2
 <u>Public Property</u>	
City Cemeteries	6
Y.M.C.A.	3
Progress for Providence	2
U.S. Post Office	4
Post Office Garage	1
Mail Box	4
Blue Cross	1
Salvation Army	1
American Red Cross	1
Children's Welfare Center	7
United Fund Agency	1
R.I. Association for the Blind	1
Redevelopment Agency	1
Weybosset Hill Development	1
 <u>Recreation Centers</u>	
Danford Street	3
Veazie Street	2
Patterson Street	2
Sackett Street	3
Gano Street	1
Warren Street	2
Washington Street	1
Valley Street	3
 <u>Parks</u>	
Hopkin's Park	2
Roger Williams Park	24
Richardson Park	4
Marino Park	10
Davis Park	12
Neutaconkanut Park	5
Triggs Park	2
Rear 51 Rowley Street	1
 <u>Outside City</u>	
Howard State Institution	10

The following is a list of runs responded to by Rescue Companies of the Providence Fire Department for the period of June 1, 1967 to May 31, 1968:

<u>Colleges</u>	<u>No. of Runs</u>
Brown University	10
Rhode Island School of Design	2
Rhode Island College	10
Providence College	2
Johnson and Wales Jr. College	3
Rhode Island Jr. College	1
University of Rhode Island Extension	1
 <u>High Schools</u>	
LaSalle Academy	4
Rhode Island Vocational	1
Moses Brown	1
 <u>Grammar Schools</u>	
Holy Name School	1
St. Michael's School	1
Henry Barard School	2
Assumption School	1
 <u>Convents</u>	
St. Xavier's Convent	1
 <u>Churches</u>	
St. Bartholmew's Church	1
St. Charles Church	1
St. Theresa's Church	1
St. Michael's Church	1
St. Pius Church	2
St. Raymond's Church	2
Mt. Carmel Church	1
St. Francis' Chapel	2
Cathedral St. John the Devine	1
Cathedral Sts. Peter & Paul	1
Cathedral Rectory	1
 <u>Hospitals</u>	
Roger Williams General Hospital	3
Butler Health Center	1
Lying In Hospital	2
Charles V. Chapin Hospital	3
Rhode Island Hospital	1
 <u>Bridges</u>	
Washington Bridge	8

Public Buildings

No. of Runs

Y.M.C.A.	16
Olneyville Boy's Club	3
Cranston Street Armory	1
Internal Revenue Building	1
Public Transit Auth. Bldg.	1
Superior Court	5
6th. District Court	1
State House	13
City Hall	5
Post Office	7
Family Court	1

TOTAL NUMBER OF RUNS

RESCUE RUNS	126
OTHER THAN BUILDING FIRES	292
BUILDING FIRES	44

During the period from June 1, 1967 to May 31, 1968 the Police Department reports that there have been seven arrests for arson and all seven cases are pending.

James T. Killilea
Chief of Department

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL

No. 108

Approved August 21, 1968

WHEREAS, for the past number of years the former Roosevelt Street School has been in a dilapidated state and has not been used as originally intended causing much criticism from owners of property and tenants in its vicinity, and

WHEREAS, the subject school building was some time ago to have been turned back to the City Administration as no longer useful for school purpose.

NOW THEREFORE BE IT RESOLVED, That the School Committee is requested to order the transfer of the said Roosevelt Street School back to the City Administration.

IN CITY COUNCIL

AUG 15 1968

READ and PASSED

President

Clerk

APPROVED

AUG 21 1968

MAYOR

RESOLUTION
OF THE
CITY COUNCIL

IN CITY
COUNCIL

JUL 6 1967

FIRST READING
REFERRED TO COMMITTEE ON
PUBLIC WELFARE
Committee Clerk

THE COMMITTEE ON
PUBLIC WELFARE

Recommends FEB 8 1968

to be continued

William S. Williams
First Deputy City Clerk

THE COMMITTEE ON
Approves Passage of
The Within Resolution

William S. Williams
Chairman
Aug 21, 1968
Concurrence

Concurrence

DEPARTMENT OF PUBLIC SCHOOLS
170 POND STREET
PROVIDENCE 3, R.I.

CHARLES A. O'CONNOR, JR.
SUPERINTENDENT

MEMORANDUM

To: Mr. Vincent Vespia, City Clerk
From: Dr. Charles A. O'Connor, Jr., Superintendent of Public Schools
Date: September 26, 1967
Subject: Your memorandum, dated July 21, 1967, re: Roosevelt Street School being transferred back to the City Administration

At the meeting of the School Committee on September 25, 1967, your memorandum of July 21, 1967, and the accompanying resolution were read to the members.

The following statement met with their approval:

On November 27, 1961 Resolution 615, approving the ~~disposal of the~~ disposal of the Roosevelt Street Elementary School was passed by the Providence School Committee; and turned over to the City Council for any disposition that the said body would deem advisable. *expense please*

On November 16, 1962, the Providence City Council passed its Resolution 593, approving and authorizing the continued use of Roosevelt Street Elementary School by the Providence School Department.

The building was refurbished and prepared for use for a maintenance headquarters, and is presently housing a variety of maintenance shops.

When the Vocational building is built, the vocational shops at Bough Street will be moved, and the maintenance shops, now housed at Roosevelt Street Elementary School building, will be moved to Bough Street.

FILED

SEP 27 1 54 PM '67

DEPT. OF CITY CLERK
PROVIDENCE, R. I.

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL

No. 143

Approved August 21, 1968

RESOLVED, that the Director of the Department of Recreation, and the Director of the Department of Planning and Urban Development, are requested to construct a regulation little league baseball field upon that vacant area bounded by Rachel, Rugby and Autumn Streets and Thurbers Avenue, the field to be utilized until the area is incorporated as a part of the Model Cities Plan scheduled for that immediate section of the City.

IN CITY COUNCIL

AUG 15 1968

READ and PASSED

President

Clerk

APPROVED

AUG 21 1968

MAYOR

FILED

MAR 27 9 18 AM '68

DEPT. OF CITY CLERK
PROVIDENCE, R. I.

RESOLUTION
OF THE
CITY COUNCIL

IN CITY
COUNCIL

APR 4 1968

FIRST READING
REFERRED TO COMMITTEE ON
PUBLIC WELFARE.....

Amant Cooper
CLERK

THE COMMITTEE ON

Public Welfare

Approves Passage of
The Within Resolution

Amant Cooper

August 2, 1968
Amant Cooper
CLERK

Councilmen McKeen and McNeely

RESOLUTION OF THE CITY COUNCIL

No. 774

Approved August 21, 1968

RESOLVED, That the Director of the Department of Building Inspection is requested to cause an inspection to be undertaken of the Merino School building for the purpose of determining whether the structure is safe for occupancy.

IN CITY COUNCIL

AUG 15 1968

READ and PASSED

President

Clerk

APPROVED

AUG 21 1968

MAYOR

RESOLUTION
OF THE
CITY COUNCIL

IN CITY
COUNCIL

FEB 1 - 1968

FIRST READING
REFERRED TO COMMITTEE ON
PUBLIC WELFARE
Samuel Cooper, CLERK

THE COMMITTEE ON

PUBLIC WELFARE
Recommends

Walter J. West
First Deputy City Clerk

FEB 8 1968

To be continued

THE COMMITTEE ON

Public Welfare
Approves Passage of
The Within Resolution

Samuel Cooper
Clerk
Aug 2, 1968

Commissioner W. Murphy



Vincent DiMase, P. E.
Director

CITY OF PROVIDENCE . MAYOR JOSEPH A. DOORLEY, JR.

Department of Building Inspection

112 Union Street, Providence, R. I. 02903
831 - 6500

Peter J. Hicks, Jr.
Deputy Director
Chief Electrical Inspector
Nicholas DiBenedetto
Chief Inspector of
Structures and Zoning
Lloyd Salisbury
Chief Mechanical Inspector
Joseph B. Dempsey
Chief Plumbing, Drainage
and Gas Piping Inspector

February 8, 1968

Committee on Public Welfare
Department of City Clerk
City Hall

Gentlemen:

At your request, this Department has made an inspection of the Merino School located at 181 Glenbridge Avenue, on February 7, 1968, and the following are our findings:

1. Building is a two-story and basement frame structure containing four classrooms, two on each floor.
2. Building is completely sprinklered, including loft space.
3. Exits consist of unprotected wooden stairs from the basement to the second floor.
4. Classrooms on each floor open out directly onto front and rear stairways. Stairways at the first floor level terminate into front and rear entrance vestibules which in turn open out directly to front and rear yards.
5. Exits from basement consist of two stairways to the first floor and two bulkheads leading directly to side yards. Stairways and bulkheads are so laid out that boys and girls toilet rooms have ready access to both stairways and bulkheads.
6. All exterior doors including bulkhead doors are equipped with panic hardware as required.
7. Ceiling of basement completely exposed. Boiler room has no protective ceiling and no protective wall enclosure. Boiler is oil fired.

8. Building equipped with fire alarm stations on each floor and main fire alarm call box connected with Fire Department on the first floor in front entrance vestibule.

9. Doors opening from classrooms to stairways are wood with glass transoms over same. Doors not self-closing.

10. Each floor provided with fire extinguisher.

11. No fire escape on building.

12. Noticed wet spots in second floor plaster ceilings.

13. Stairway treads covered with steel anti-slip treads.

14. Stairways open at basement level. Stairway soffits from basement to second floor unprotected.

15. Exterior of building:

Following noted:—

(a) Loose and missing clapboards.

(b) Missing rain conductors at two corner of building.

(c) Dangerous condition of exterior stairs from grade to first floor.

Recommendations:

General overall structural condition of building satisfactory. However, the following repairs and improvements should be made in order to provide maximum safety for those who occupy the building:

1. Repair exterior walls—nail tight all loose clapboards and replace those fallen off.

2. Replace two rain conductors.

3. Replace missing rails on front entrance steps and repair stair platform.

4. Renew completely rear exterior stair platform - present platform patched up and not level.

5. Block up all transoms over doors opening into stairways and install closers on all stairway doors.

6. Enclose boiler room with cement blocks, protect ceiling with fire proof wall board or lath and plaster, and install fire door on opening.

7. Cover stairway soffits from basement to second floor with fire-resistive covering.

8. Boiler room not to be used for storage of any kind of combustibile materials or items.


9. Replace all broken glass.

10. Check roof for leaks which are the cause of wet spots in second floor plaster ceilings.

11. Exterior of building badly in need of painting.

If you have any questions please call me.

Very truly yours,


Vincent DiMase, Director
Department of Building Inspection

VDM/np

THE CITY OF PROVIDENCE
STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

RESOLUTION OF THE CITY COUNCIL

No. 1175

Approved August 21, 1968

Resolved,

That the following named person, firm or corporation is hereby granted permission to erect, alter or use a building or structure at the location named herein for the sale of petroleum, kerosene, gasoline, coal oil and their products, compounds and components as described and shown in and on the application therefor and accompanying plat, all on file in the Office of the Department of Building Inspection subject to the conditions that said person, firm or corporation shall not violate any of the laws of the State of Rhode Island or any of the Ordinances of the City of Providence relative to the erection, use or occupation of said structure and that said person, firm or corporation shall not allow petroleum, kerosene, gasoline, coal oil or their products, compounds or components, to be conveyed over or across any sidewalk by means of any pipe or hose, and upon such special conditions as are hereby enumerated and further provided that the Director of the Department of Building Inspection may authorize minor changes in the structural detail of plans on file, viz:

Vincent Duva, 435 Mount Pleasant Avenue, Plat 128, Lot 16, install One (1) new six thousand (6,000) Gallon tank, remove two (2) single pumps and install three (3) dual pumps, relocate existing four thousand (4,000) Gallon tank; making a total storage capacity of eighteen thousand (18,000) Gallons upon the premises.

The erection or location of any buildings or structures not shown on the original plat on file with the Director of Department of Building Inspection, or any change in the location of buildings or structures from that shown on said plat shall be deemed a violation of this permit.

IN CITY COUNCIL

AUG 15 1968

READ and PASSED

[Signature]
President
[Signature]
Clerk

APPROVED

AUG 21 1968

[Signature]
MAYOR

THE COMMITTEE ON

W. W. Keenan
Approves Passage of
The Within Resolution

Samuel H. Hays
August 2, 1951
W. W. Keenan

CITY OF PROVIDENCE
DEPARTMENT OF CITY CLERK
CITY HALL
PROVIDENCE, RHODE ISLAND

Notice is hereby given that a Public Hearing will be held before the Committee on Licenses of the City Council on Wednesday, August 7, 1968 starting at 3:00 o'clock p. m. relative to the following:

APPLICATION OF VINCENT DUVA, 435 Mount Pleasant Avenue, Plat 128, Lot 16, install one (1) new six thousand (6,000) gallon tank, remove two (2) single pumps and install three (3) dual pumps, relocate existing four thousand (4,000) gallon tank; making a total storage capacity of eighteen thousand (18,000) Gallons upon the premises.

APPLICATION OF TEXACO, INC., 540 Allens Avenue, Plat 55, Lot 196, install two (2) pumps; making a total of four (4) gasoline filling pumps upon the premises.

APPLICATION OF SOFIA REALTY COMPANY, 692, 694, 700 Hartford Avenue and 359 Killingly Street, Plat 115, Lots 543, 545 and parts of 551 and 552, new gasoline service station building, install sixteen thousand (16,000) gallons in four (4) tanks, one thousand (1,000) gallons of fuel oil in tank and one thousand (1,000) gallons waste oil tank; making a total storage capacity of four (4) four thousand (4,000) gallons gasoline; one (1) one thousand (1,000) gallons fuel oil and One (1) one thousand (1,000) waste oil upon the premises.

APPLICATION OF BARMAL REALTY CORP., Smithfield Avenue, Plat 77, Lot 789, new gasoline service station, install three (3) gasoline filling pumps, install two (2) six thousand (6,000) gasoline tanks, one (1) four thousand (4,000) gasoline tank and two (2) five hundred fifty (550) fuel and waste oil tank; making a total storage capacity of sixteen thousand (16,000) gallons upon the premises.

BY ORDER OF THE COMMITTEE ON LICENSES
COUNCILMAN PETER C. MORAN - CHAIRMAN

Vincent Vespia

VINCENT VESPIA
CITY CLERK

July 19, 1968

I approve the above installation of the new gasoline tanks and approve the application of Vincent Duva, located at 435 Mount Pleasant Providence, Rhode Island because this gasoline station serves motorists in this area and also performs a public service by the convenience of this gasoline station.

Edward S. A. Altieri
313 Whitford Avenue
Providence, R. I. 02908

APPLICATION FOR PERMIT FOR GASOLINE STATION

Providence, 5-20-1968

To the Director of the Department of Building Inspection:

The undersigned hereby applies for permission to erect gasoline station specified as follows:

1. 2 Building District 5 Ward
2. Street Location 435 MT Pleasant Ave
3. Plat 128 Lot 16
4. Owner Vincent DiMaso
5. Number of Pumps 4 (New Station) Empty
6. Number of Buildings 1
7. Number of Curb Cuts 3 Width 20
8. Drawings Accompanying Application 5
9. Number of Pumps Now on Premises 4
10. Number of Additional Pumps 4 Total on Lot (8)
11. Capacity of Tanks (Existing) 4000 - 4000 - 2000 - 2000 - Gals
12. Capacity of Additional Tanks 6000 Gals
13. Total Capacity on Lot 18,000 Gals
14. Is Gasoline or Oil to Be Sold? Y-1
15. Zoning District R-1
16. Estimated Cost 1000

Approved: [Signature]
Commissioner of Public Safety

Approved: [Signature]
Traffic Engineer

Approved: [Signature]
Director of Public Works

Approved: [Signature]
Director of the Department of Building Inspection

REMARKS
List of additional coal oils, compounds and components to be stored and sold.

Product	Quantity	Pumps Used
install new	6000 gal Tank	
Recoat	1 - 4000 gal Tank	
install	3 - 2000 gal Pumps	
Recoat	2 - 2000 gal Pumps	

[Signature]
Owner's Name


435 Mt Pleasant Ave
Address

Agent's Name


Agent's Address

Telephone Number

INSPECTED & APPROVED
BUREAU OF FIRE PREVENTION


Chief

APPROVED:


Chief of Department

FILED
JUN 25 3 54 PM '68
DEPT. OF CITY CLERK
PROVIDENCE, R.I.

Plat 128

Lot

- 2 City of Providence School Department
Pond Street
- 13 Agnes J. Rustigian
419 Mt. Pleasant Avenue
- 15 Jasper H. Fiocca & wf. Ismalia
431 Mt. Pleasant Avenue
- 17 James Santaniello & wf. Gilda
110 Freese Street

Plat 116

Lot

- 11 & 234 Edward S. A. Altieri
313 Whitford Avenue
- 114 Louis Zannelli & wf. Mary (65)
96 Freese Street
- 189 Joseph Buccini & wf. Lydia
308 Whitford Avenue
- 190 James Santaniello & wf. Gilda
110 Freese Street
- 235 Peter Campanelli & wf. Annette
307 Whitford Avenue
- 264 Alfred M. Kenyon Estate and wid. Mary F. &
Alfred H. Kenyon
c/o Providence Journal Credit Union
Fountain Street
- 191 Louis Zannelli
96 Freese Street
- 237 John McCaffrey
301 Whitford Avenue



CITY OF PROVIDENCE, RHODE ISLAND

ZONING BOARD OF REVIEW

112 UNION STREET

02903

John R. Davis, Secretary

March 7, 1968

RESOLUTION NO. 3320

Vincent Duva
89 1/2 Charles Street
Providence, Rhode Island

Dear Sir:

At a meeting of the Zoning Board of Review held on Tuesday, March 5, 1968, the following resolution was adopted:

WHEREAS, Vincent Duva, owner of Lot 16 on Assessor's Plat 126 (435 Mt. Pleasant Avenue) in a Residence R-1 Zone, on January 17, 1968, filed an application for permission to be relieved from Section 41-A of the Zoning Ordinance in the proposed installation of an additional 8,000 gallon underground gasoline storage tank, making a total storage of 18,000 gallons in all and the replacing of two single pumps with three dual pumps on the above described premises, and

WHEREAS, on February 13, 1968, the members of the Zoning Board of Review made an inspection of the above described premises and also of the surrounding properties and noted that property was very well kept, and

WHEREAS, a public hearing was held on this application by the Zoning Board of Review at its meeting held on Tuesday, February 13, 1968, after public notice as provided by the Zoning Ordinance, at which time it was held for further consideration,

RESOLVED: That the Zoning Board of Review does hereby make the variance of Section 41-A under the Zoning Ordinance and does hereby grant the application of Vincent Duva, substantially in accordance with the plans and plot plans filed with said Board, provided that the use of the existing 4,000 gallon tank located on the southern property line be discontinued and tank either be removed or dry-filled and a new 4,000 gallon tank be installed on the north, northwesterly side of said premises and further provided that all remote fills and vents be relocated to the north side of premises subject to the approval of the Department of Building Inspection. A copy of said plans and plot plan are hereby made a part of this resolution and filed with the Director of the Department of Building Inspection.

By Order of the Zoning Board of Review.

FRANK A. BELL GESSO
CHAIRMAN

ATTENTION: SECTION 92-A UNDER THE ZONING ORDINANCE REQUIRES THAT YOU APPLY TO THE DIRECTOR OF THE DEPARTMENT OF BUILDING INSPECTION FOR A PERMIT AND/OR A CERTIFICATE OF OCCUPANCY WITHIN SIX MONTHS FROM THE DATE OF THE ADOPTION OF THIS RESOLUTION. UNLESS YOU COMPLY WITH SAID REQUIREMENT, THIS RESOLUTION WILL BECOME INVALID.

JRD:mt
oct A. Bucol, Esq.
City Clerk